



Northwestern Water & Sewer District
WL-100/101 Valve Improvements

ADDENDUM 1

December 3, 2025

Planholders of the Northwestern Water & Sewer District, WL-100/101 Valve Improvements, project are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

QUESTIONS FROM BIDDERS

The following questions were received during the bid period. Answers are provided following each question.

Question #1: Is there a contract percentage clause on the Prime Bidder in relation to sub-contractor price?

No. There is no percentage prime requirement on this contract.

Question #2: Will you allow 24" DIPS DR 11 HDPE be allowed for the bypass?

This is acceptable. The pipe will need to be disinfected and tested.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PAGE C-410 - 1 OF THE BID.