



---

City of Maumee, Ohio  
Lochhaven Area Water Line Replacement

---

**ADDENDUM 1**

---

May 16, 2019

Planholders of the City of Maumee Water Line Replacement are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

**SPECIFICATIONS**

Page 01010-8 7.01

Add the following Paragraph H.

“H. The replacement of pavement markings in areas where the pavement is milled shall be included in these Items.”

Page 01010-9 7.05 F

Add the following to Paragraph F.

“The placement of new asphalt on Detroit Avenue shall include the replacement of existing pavement markings.”

Page

Page 02558-3

Add the following Paragraph 4.01

“4.01 CURB BOXES

A. Curb boxes shall be Bingham & Taylor Model number 9401.”

**QUESTIONS**

The following responses are provided for questions received during the bid period.

**Question #1 – Will Detroit Ave. require restriping after the mill and overlay is complete? If so can you provide a spec for the striping.**

Yes, striping is required. See Addendum 1 for clarification and Specification Section 02600, 2.07.

**Question #2 – Also is there any granular that is required on the open cut service connections?**

The specified requirements for bedding applies to all pipe construction, including water services. This should be understood to mean the provision of Type B backfill for pipes below the zone of influence line for paved areas as defined in the specifications and details for the project.



City of Maumee, Ohio  
Lochhaven Area Water Line Replacement  
165-7487.001  
Addendum No. 1

**Question #3 - Will the city be performing the work, and the contractor providing the material similar to the tapping sleeve and valve for Detroit Ave. tie in?**

No, tapping sleeves and valves are to be provided by the Contractor as specified.

**Question #4 - In regards specification section 2558 3.03 H 2b 1.) “FLSR – If the property owner opts to have the private pipe replaced, the work will be included in the construction contract.” Will this be paid for under bid item 5a?**

Lead is not known to exist in the project area.