



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
architects@beilharzinc.com

May 23, 2019

DEFIANCE COMMUNITY AUDITORIUM AIR CONDITIONING
Defiance, Ohio

B9-4626

ADDENDUM NO. 1

This Addendum becomes a part of the Contract Documents and modifies them only to the extent herein set forth. Each bidder is responsible for distribution of information conveyed by this Addendum to its subbidders and suppliers.

ITEM NO. 1: Sheet A-103 – Roof Framing Plan and Details

Roof Mounted Equipment Curb 2: New wood framing and blocking shall be fire retardant treated wood.

END OF ADDENDUM