

**VILLAGE OF NEW BREMEN, OHIO
WASTEWATER TREATMENT PLANT LAGOON 2 SLUDGE REDUCTION**

**Addendum No. 1
April 15, 2026**

To: Prospective Bidders
From: **ARCADIS U.S., Inc.**
One Seagate, Suite 700
Toledo, Ohio 43604
Owner: **Village of New Bremen Ohio**
214 N. Washington St., P.O. Box 27
New Bremen, Ohio 45869
Subject: **Wastewater Treatment Plant Lagoon 2 Sludge Reduction**

This Addendum is part of the Bidding Documents and the Contract Documents and modifies the original Bidding Documents advertised dated **April 3, 2026**, as indicated below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification for award of the associated Contract.

This Addendum consists of 2 pages.

RFI's

1. Please confirm there are no dewatering processing rate restrictions if the effluent is returned to the lagoon instead of the 65 gpm listed in the 1.7 requirements and the manhole that is only rated for 250 gpm.

Response:

Dewatering filtrate is required to be retreated through both lagoons. The process rate limitations, as described in Section 33 01 30.52 Part 1.7, are based upon WWTP treatment capacity and anticipated loadings in the dewatering filtrate.

Section 33 01 30.52 Part 1.7.C.1.b.1 specifies that the Owner may accommodate an increase to the maximum sludge feed rate based upon monitoring plant operations and WWTP limitations, but it is at the Owner's sole discretion.

CHANGES TO PRIOR ADDENDA

None.

CHANGES TO BIDDING REQUIREMENTS

- 1.01 Page 00 11 13-1 ADVERTISEMENT FOR BIDS, Paragraph 1 – In Paragraph 1, delete the first sentence in its entirety and substitute the following:

“Sealed Bids for the construction of the Wastewater Treatment Plant Lagoon 2 Sludge Reduction will be received by the Village of New Bremen, Ohio 45869, at the office of the Village Administrator, 214 N. Washington St. P.O. Box 27, until **2 p.m. local time on May 1, 2026**, at which time the Bids received will be publicly opened and read.”

CHANGES TO SPECIFICATIONS

None.

CHANGES TO DRAWINGS

None.

ATTACHMENTS

None.

END OF ADDENDUM NO. 1