



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
architects@beilharzinc.com

March 31, 2023

DEFIANCE COUNTY EAST
Storage Building
Defiance, Ohio

C2-4854

ADDENDUM 2

This Addendum becomes a part of the Contract Documents and modifies them only to the extent herein set forth. Bidders shall acknowledge receipt of this Addendum on the Bid Form. Each bidder is responsible for distribution of information conveyed by this Addendum to its subbidders and suppliers.

Attachments: Bid Question Log #2

ITEM NO. 1: Sheet C-102 – Site Utility Plan

Refer to attached bid question for clarification.

END OF ADDENDUM



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
architects@beilharzinc.com

March 31, 2023

DEFIANCE COUNTY EAST
Storage Building
Defiance, Ohio

C2-4854

BID QUESTION LOG #2

The following questions and answers are distributed for supplemental information and clarification, and are not part of the Contract Documents. Questions answered by Addendum items are not necessarily repeated in this document.

- Q3. Since the gas line is now to be tied in to the existing line prior to the exiting meter and not after it, can you verify that you still want the contractor to take care of this?
- A. The tie-in location is not a change. Coordinate work with the utility company and pay utility company charges in accordance with Section 01 3100 – 1.04.C.

END OF BID QUESTION LOG #2