



Northwestern Water and Sewer District
McComb Water Line Replacement – Phase 3
WL-2818

ADDENDUM 2

October 15, 2021

Planholders of the Northwestern Water and Sewer District, McComb Water Line Replacement – Phase 3 WL-2818 project are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

DRAWINGS

On Sheet W-4.2, East Perrin Avenue, replace “ 8”x 8” Tee” with “ 8” x 6” Tee,” and replace “ 6”x 8” Tapping Sleeve, Valve and Box” with “ 6” Gate Valve and Box.”

Quantities will not be adjusted for these changes for the purpose of bidding.

QUESTIONS

The following questions were submitted to the Engineer. The answers provided below are for the clarification of Bidders questions. Questions have been paraphrased for brevity.

Question #1 – What size are the meters being installed.

See Specification 02558, 4.10 A.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PAGE C-410 - 1 OF THE BID.