



Department of Public Service
5330 Seaman Road
Oregon, Ohio 43616
(419) 698-7047
FAX (419) 691-0241

June 8, 2022

ADDENDUM No. 1
2022 ROAD IMPROVEMENT PROGRAM

CITY OF OREGON
DEPARTMENT OF PUBLIC SERVICE

BIDS TO BE OPENED: Wednesday, June 15, 2022 at 2:00 P.M.

Plan holders of the City of Oregon's 2022 Road Improvement Program are hereby notified of the following amendments to the Contract Documents. The following additions, alterations, deletions and/or clarifications shall be part of the Base Bid as much as if they were originally included in the Contract Documents. This Addendum No. 1 is hereby made a part of the Contract Documents.

CONTRACT CHANGES

1) Change of Completion Date for All Projects

Completion Date revised from September 30th, 2022 to **October 21st, 2022** for all projects.

2) Change of Project Descriptions


In paragraph one of "STAGE 2" of "CONSTRUCTION SEQUENCING" for Projects #2, #3, and #4, delete "Contractor shall excavate, form and pour the curb with MS concrete all within the same day." and insert "**Access to driveways shall be maintained until the afternoon the day before curb is poured. Access shall be restored once MS curb has cured.**"

3) Additional Information

Below is the detail for the Lucas County Type F Curb:



Department of Public Service
5330 Seaman Road
Oregon, Ohio 43616
(419) 698-7047
FAX (419) 691-0241



NOTES

CURB, TYPE F SHALL BE CONSTRUCTED ACCORDING TO ITEM 609.04 OF THE CURRENT STATE OF OHIO DEPARTMENT OF TRANSPORTATION CONSTRUCTION AND MATERIAL SPECIFICATIONS, EXCEPT FOR THE FOLLOWING:

CONSTRUCT 1/4" WIDE CONTRACTION JOINTS AT EIGHT FOOT (8') INTERVALS TO A DEPTH OF TWO INCHES (2").

CONSTRUCT 1" EXPANSION JOINTS AT 250' INTERVALS IN ACCORDANCE WITH OHIO DEPT. OF TRANSPORTATION ROADWAY STD. DWG. BP-2.2.

FOR CURB, TYPE F, REPAIR/REPLACEMENT WORK, THE NEW CURB, TYPE F, SHALL BE TIED TO THE EXISTING CURB, TYPE F, UTILIZING TWO EACH #5x18" TIE BARS OR HOOK BOLTS, IN ACCORDANCE WITH ODOT STD. DWG. BP-2.1.

ITEM 609 CURB, TYPE F

4) Question from Bidder

Would you consider raising the estimates with current material and fuel prices?

Answer: We do not plan to revise estimates. The City understands prices are higher due to inflation. However, there is no federal or state funding for these projects and the City is not obligated to meet the 10% over estimate rule. Unless there is a major design error, the City does not plan to rebid these projects.

***** END OF ADDENDUM NO. 1 *****

Paul Roman, P.E.
Director of Public Service