



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
architects@beilharzinc.com

May 28, 2020

EVERGREEN LOCAL SCHOOLS
Summer 2020 Projects
Metamora, Ohio

B7-4569

ADDENDUM NO. 4

This Addendum becomes a part of the Contract Documents and modifies them only to the extent herein set forth. Each bidder is responsible for distribution of information conveyed by this Addendum to its subbidders and suppliers.

ITEM NO. 1: Sheet EF001 – Fire Alarm Legend

Fire Alarm Riser: Interconnect High School FAP and Middle School FAP using existing copper wiring connection.

ITEM NO. 2: Sheet EF101 – Elementary Partial First Floor Fire Alarm Plan

Secretarial 203: Add cabinet for fire alarm microphone and report printer at FAA.

ITEM NO. 3: Sheet EF111 – Middle School Partial First Floor Fire Alarm Plan

Waiting 102: Add report printer.

ITEM NO. 4: Sheet EF113 – High School Partial First Floor Fire Alarm Plan

Reception B102: Add cabinet for fire alarm microphone and report printer at FAA.

ITEM NO. 5: Sheet EF115 – High School and Bus Garage Partial First Floor Fire Alarm Plans

Bus Garage: Remove existing FAP in Janitor A106 and install new in same location.

ITEM NO. 6: Sheet EF701 – Fire Alarm Specifications

Section 284621, paragraph 2.03.G: Key all panels alike.

END OF ADDENDUM