



---

Northwestern Water and Sewer District  
East Union Street Water Main Replacement, WL-164I

---

**ADDENDUM 3**

---

5/5/26

Planholders of the Northwestern Water and Sewer District, East Union Street Water Main Replacement, WL-164I project, are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

**SPECIFICATIONS**

Specification 01010, 5.01, revise to read:

“F. The installation and relocation of meter pits shall be included under these Items. Meter pits and meters shall be provided by the Owner. Water meters installed by the Contractor.”

**DRAWINGS**

Plan sheet W-0.1, Section 2.2. Delete Paragraph C discussing fused PVC Pipe. Fused PVC pipe is not to be permitting for this project.

**RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PAGE C-410 - 1 OF THE BID.**